# **Model 100J3**

**Diaphragm Seals for Saddle Weld Process Connections Standard Pressure Rating with Metal Lower Housings Complete with Clean-out Option** 

#### **Process Connection Sizes**


3" and larger

All Pipe Schedules per ASME/ANSI B36.10 or B36.19

#### **Maximum Working Pressure**

Conforms to Pipe Schedule Ratings as calculated by ASME B31.1 Equation "4" @ 100°F (38°C) (See Notes 3, 4, 5 and 8)

#### **Dimensional Data**



#### **Standard Features and Options**

able diaphragm clamped between o-rings. The 100J3 Series Seals are designed to utilize a diaphragm that is field replaceable. This configuration allows for the use of metal as well as elastomer diaphragm materials. Recommended for applications that require a continuous flow of process across the diaphragm to insure that pres-sure sensing is not inhibited by solids buildup. The 100J3 Series Seals utilize a "Clean-out" feature which is a separate diaphragm clamping ring that permits removal of the lower housing for welding of lower, inspection, or cleaning of the diaphragm without loss of fill fluid. The displacement capability of this series of diaphragm seal is 0.09 cubic inches. The Seal-off feature is optional.

#### Offerings

Lower Materials: All metallic

**Upper Materials**: Carbon Steel or 316 Stainless

Steel

Diaphragm Materials: All metallic and elastomers

O-Rings: Buna-N, Teflon, Viton


**Bolting:** Carbon Steel or 300 Stainless Steel

(See Notes 3, 4, 5 and 8)

#### **CONTROL ENGINEERING DATA**

A7SLBJ IHCBCO HAN

CATALOG NUMBERS AS RECEIVED FOR THE 100J3 SERIES MUST CONTAIN FIFTEEN (15) CHARACTERS



## Notes:

- 1. Standard diaphragm material is 316L Stainless Steel for seals with lower housing manufactured of CS, S4, S6, SL and SF.
- 2. Teflon o-rings cannot be used on seals with pipe schedules greater than 40.
- 3. Using Grade 5 bolts will maintain the pressure rating calculated from the Pipe Schedule specified in Option 6.
- 4. When using 300 Series Stainless Steel bolts, the maximum pressure rating calculated will be reduced by 50% when the pipe schedule is greater than 40 as specified in Option 6.
- 5. Pipe schedules greater than 40 will be supplied with highstrength stainless steel bolting to maintain seal pressure rating when stainless steel bolts are required.
- 6. The clean-out ring is the same material as the lower housing. 7. N.A.C.E. - Non-welded diaphragm seals with 316 Stainless Steel, Hastelloy C-276 or Monel wetted materials of construction will meet the requirements of N.A.C.E. International Document MR-
- 8. Refer to Miscellaneous Data Section for ASME B31.1 Equation "4."
- 9. Teflon-S® Coating (FEP Grade).

This saddle weld connection seal has a replace-

@ 100°F (38°C) (See Notes 3, 4, 5 and 8)

H= Schedule 5

I = Schedule 10

J = Schedule 40 (Standard)

K= Schedule 80

L = Schedule 160

### (5) SEAL PROCESS CONNECTION

### (3-4) LOWER HOUSING MATERIAL(WETTED)(See Note 6)

C2 = Carpenter 20 CB-3

CS= Carbon Steel

HB= Hastelloy B3 HC= Hastelloy C-276

16 = Inconel 600 M4= Monel 400

N2 = Nickel 200

S4 = 304 Stainless Steel

S6 = 316 Stainless Steel SF = 304L Stainless Steel

SL = 316L Stainless Steel

TI = Titanium - Grade 4

### 1-2) DIAPHRAGM SEAL DESIGN

A7 = 100J3 Saddle Weld In-Line